

CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Audit Information:

Utility: City of EL Segundo.

PWS ID: 1910040

System Type: Potable

Audit Period: Calendar 2018

Utility Representation:

Luci Cummings (Administrative Technical Specialist)

Validation Date: 6/25/2019

Call Time: 11am

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 69 Data Validity Band (Level): Band III (51-70)

ILI: 0.25

Real Loss: 3.59 (gal/conn/day)

Apparent Loss: 1.31 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 0.2%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Tanmay Thakur and Aretha Samuel Validator Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided